



CERTIFICATE OF CONFORMITY

SAI Global hereby grants:

Brightwell Dispensers Ltd

Unit 1 Rich Industrial Estate, Avis Way, Newhaven, East Sussex, United Kingdom

WaterMark Certificate of Conformity

Evaluated to:

WMTS 101:2021 - Appliances (low hazard rating)

"the WaterMark Licensee" the right to use or arrange the use of the WATERMARK as shown below only in respect of the goods described and detailed on the product schedule identified on www.saiglobal.com which are produced by the WaterMark Licensee or on behalf of the WaterMark Licensee* and which comply with the appropriate Standard referred to above as from time to time amended. The Licence is granted subject to the rules governing the use of the WATERMARK and the Terms and Conditions for certification. The WaterMark Licensee covenants to comply with all the Rules and Terms and Conditions.

This Certificate is issued by a JAS-ANZ accredited certification body. The Scheme Owner, Administering Body and Accreditation Body do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The Scheme Owner disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate.

Certificate No: WMK26459

Issued : 11 May 2021
Expires : 22 May 2024

Originally Certified : 23 May 2019
Current Certification : 11 May 2021

Frank Camasta
Global Head of Technical Services
SAI Global Assurance



WaterMark



WWW.JAS-ANZ.ORG/REGISTER



ABCB

* For details of manufacture, refer to the licensee

The WaterMark is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate may only be reproduced in its entirety and remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.



SAI GLOBAL

INFORM. INSPIRE. IMPROVE.

SCHEDULE TO CERTIFICATE OF CONFORMITY

SAI Global hereby grants :

Brightwell Dispensers Ltd

Unit 1 Rich Industrial Estate, Avis Way, Newhaven, East Sussex, United Kingdom

WaterMark Certificate of Conformity

Evaluated to:

WMTS 101:2021 - Appliances (low hazard rating)

Model identification of the goods on which the WATERMARK may be used:

Model Identification	Model Name	Product Type	Backflow Prevention Method	Brand Name	Inlet Designation	Product Description	Date Endorsed
DPC1H1H-WK	ECOMIX 2 PRODUCT COMPACT HIGH FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPC1H1H-WK/AG	ECOMIX 2 PRODUCT COMPACT HIGH FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPCL1H-WK	ECOMIX 2 PRODUCT COMPACT LOW FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPCL1H-WK/AG	ECOMIX 2 PRODUCT COMPACT LOW FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPCL1L-WK	ECOMIX 2 PRODUCT COMPACT LOW FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPCL1LWK/AG	ECOMIX 2 PRODUCT COMPACT LOW FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPCHB-WK	ECOMIX COMPACT HIGH FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPCHBWK/AG	ECOMIX COMPACT HIGH FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPCLBB-WK	ECOMIX COMPACT LOW FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPCLBBWK/AG	ECOMIX COMPACT LOW FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPHB-WK	ECOMIX HIGH FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DPLB-WK	ECOMIX LOW FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMIX	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DX4H-WK	ECOMULTI HIGH FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021

Certificate No: WMK26459

Issued Date: 11 May 2021

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The WaterMark is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate may only be reproduced in its entirety and remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.

SCHEDULE TO CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Product Type	Backflow Prevention Method	Brand Name	Inlet Designation	Product Description	Date Endorsed
DX4H-WK/AG	ECOMULTI HIGH FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DX4L-WK	ECOMULTI LOW FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DX4L-WK/AG	ECOMULTI LOW FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DXC4H-WK	ECOMULTI COMPACT HIGH FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DXC4H-WK/AG	ECOMULTI COMPACT HIGH FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DXC4L1HWK	ECOMULTI 5 PRODUCT COMPACT, LOW/HIGH FLOW BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DXC4L1HWK/AG	ECOMULTI 5 PRODUCT COMPACT, LOW/HIGH FLOW AIRGAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DXC4L1L-WK	ECOMULTI 5 PRODUCT COMPACT LOW FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DXC4L1L-WK/AG	ECOMULTI 5 PRODUCT COMPACT LOW FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DXC4L-WK	ECOMULTI COMPACT LOW FLOW, BRIGHTGAP	BRIGHTGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in IEC 61770	Pipe interrupter with atmospheric vent & moving element	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021
DXC4L-WK/AG	ECOMULTI COMPACT LOW FLOW, AIR-GAP	AIRGAP Evaluated to: WMTS 101:2018, complying with the Backsiphonage test detailed in AS2845.2:1996	25mm air gap	ECOMULTI	3/4 G	Wall Mounted Chemical Dilution System	11 May 2021

End of Record

Certificate No: WMK26459

Issued Date: 11 May 2021

This schedule supersedes all previously issued schedules

Registered by:

The WaterMark is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate may only be reproduced in its entirety and remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.

